



100-01 TRAINING MATERIAL CORRECTIONS

Please note the following corrections to the 100-01 course materials.

This bulletin affects the English version of the course only as the French version is slightly older. An updated French version will be released at a later date to be determined.

100-01 PROPANE PUMP ATTENDANT COURSE MANUAL

Page 21, review question #4 should read:

“The **80%** fixed liquid level gauge is commonly referred to as a _____ .”

NOT:

“The **90%** fixed liquid level gauge is commonly referred to as a _____ .”

100-01 PROPANE PUMP ATTENDANT EXAM

Question 27 is worded as follows:

“When offering for transport or transporting five or less cylinders, the Transportation of Dangerous Goods regulations require that you attach a Dangerous Goods shoulder label on all cylinders. If the customer will be transporting more than 150kg gross mass, then TDG training is required.”

While this statement is technically true, the wording could be misinterpreted. In fact, ALL propane cylinders must have a Dangerous Goods shoulder label. In regard to the part of the question regarding more than 150kg gross mass, the person transporting the cylinder(s) could avoid the training requirement if the conditions for utilizing the 500kg Gross Mass Exemption apply.

In the next printing of the exam, we will review the wording of all questions pertaining to TDG regulatory requirements. The reprinting of both the exam and course workbook are scheduled for this spring when current supplies will be exhausted.

Sent to you on behalf of:

Bill Egbert

P•T•I General Manager
800, 717-7th Avenue SW
Calgary, Alberta T2P 0Z3
begbert@propanegas.ca
Phone: 403.543.6506
Fax: 403.543.6508